

2/A

**DEPARTMENT OF PUBLIC HEALTH AND SOCIAL SERVICES
DIVISION OF ENVIRONMENTAL HEALTH**

SCHOOL BUILDING INSPECTION REPORT

REASON		INSPECTION DATE 08 / 16 / 2016	ESTABLISHMENT NAME MERCY HEIGHTS NURSERY & KINDERGARTEN	
Regular	✓	INSPECTION TIME 1 HR. 26 MIN.	OWNER/OPERATOR SISTERS OF MERCY	
Follow-up		TRAVEL TIME HR. 30 MIN.	LOCATION # 211 SAN VITORES ST., PEREZVILLE, TAMUNING	
Complaint		SANITARY PERMIT # 160000971	PERMIT CATEGORY STATUS (Circle One) Permanent Temporary Current Expired	ESTAB. TYPE SCHOOL
Investigation				
Other (Specify)				

Based on an inspection this day the items listed below identify violations in operation or facilities which must be corrected by the next routine inspection or such shorter period of time as may be specified by the Department. Failure to comply may result in cessation of your operations.

ITEM NO.	REMARKS	CORRECT BY: DATE
13	<p>A REGULAR QUARTERLY INSPECTION WAS CONDUCTED TODAY. ALL VIOLATIONS FROM PREVIOUS INSPECTION (4/A) DATED 05/11/2016 WERE CORRECTED (I.E., ITEMS # 13 & 22). THE FOLLOWING VIOLATION WAS OBSERVED TODAY:</p> <p>Ceiling tiles in the girls' restroom in the gym are stained. Covers for seven electrical outlets in the gym were missing (COS).</p> <p>Computer room still has objectionable odor but PIC voluntarily closed it since the last inspection and she said she will keep it closed until the odor problem is resolved.</p> <p>Picture of violation was taken.</p> <p>Discussed this inspection report with Helen DePant, Director.</p> <p>Issued "A" placard No. 01233.</p>	09/16/16

I have read and understand the above violation(s) and I am aware of the corrective measures to be taken.

*When any of the following items are cited above, they shall be corrected within ten days of the inspection: (01); (02); (23); (27); (31).

RECEIVED BY (Name and Title)

Helen DePant - Director

DEH INSPECTOR (Name and Title)

WILSON NAVARRO, EPH I